



State Hygienic Laboratory

The University of Iowa

JON MARTENS
ATLANTIC MUNICIPAL UTILITIES
15 W 3RD ST
ATLANTIC, IA 50022-

| | |
|-----------------------|------------------|
| Accession Number | 60924 |
| Date Sample Finalized | 2012-10-03 12:10 |
| Date Received | 2012-10-02 10:20 |
| Sample Source | Drinking Water |
| Project | |
| Date Collected | 2012-10-01 11:00 |
| Collection Site | well #6 |
| Collection Town | ATLANTIC |
| Sample Description | water |
| Client Reference | |
| Collector | parrott troy |
| Phone | 712/243-1395 |

Note: Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

Results of Analyses

GCMS Volatiles, EPA 524.2

| | |
|---------------|------------------|
| Units | mg/L |
| Date Analyzed | 2012-10-02 15:20 |
| Analyst | LJL |

| | |
|---------------|------------------|
| Analyzed In | Iowa City |
| Date Verified | 2012-10-03 12:10 |
| Verifier | JM |

| Analyte | Result | Quant Limit | MCL |
|---------------------|--------|-------------|-------|
| Tetrachloroethylene | 0.015 | 0.0005 | 0.005 |

Note: The MCL (maximum contaminant level) is only applicable to compliance monitoring samples under the Safe Drinking Water Act (SDWA).

Description of Units used within this report
mg/L = Milligrams per Liter

The result(s) of this report relate only to the items analyzed. This report shall not be reproduced except in full without the written approval of the laboratory.

Iowa Environmental Laboratory IDs are: Ankeny #397, Iowa City/Coralville #027, Lakeside #393.

If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500. Thank you.

A12Q

40479914



Superfund

0000